

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 12)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 12)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,973 mm (63 mm decrease since 16:00 on January 11)	O.P.+ 3,150 mm (21 mm decrease since 16:00 on January 11)	—
	Water level of Turbine Building	O.P.+ 3,149 mm (11 mm increase since 16:00 on January 11)	O.P.+ 2,964 mm (56 mm decrease since 16:00 on January 11)	O.P.+ 3,072 mm (57 mm decrease since 16:00 on January 11)	O.P.+ 3,099 mm (14 mm decrease since 16:00 on January 11)
	Water level of Reactor Building	O.P.+ 4,211 mm (10 mm decrease since 16:00 on January 11)	O.P.+ 3,126 mm (51 mm decrease since 16:00 on January 11)	O.P.+ 3,353 mm (50 mm decrease since 16:00 on January 11)	O.P.+ 3,119 mm (10 mm decrease since 16:00 on January 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,365 mm (Increase from initial level:5,582 mm, 117 mm increase since 16:00 on January 11) O.P.+ 3,115 mm (Increase from initial level:3,841 mm, 319 mm increase since 16:00 on January 11) O.P.+ 4,301 mm (Water level from floor:505 mm, 8 mm increase since 16:00 on January 11)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 15:45 on January 11 to 8:02 on January 12)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 15:39 on January 11 to 8:07 on January 12)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:30 on January 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:04 on January 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.