

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 12)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 12)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,011 mm (38 mm increase since 7:00 on January 12)	O.P.+ 3,147 mm (3 mm decrease since 7:00 on January 12)	—
	Water level of Turbine Building	O.P.+ 3,156 mm (7 mm increase since 7:00 on January 12)	O.P.+ 2,997 mm (33 mm increase since 7:00 on January 12)	O.P.+ 3,098 mm (26 mm increase since 7:00 on January 12)	O.P.+ 3,087 mm (12 mm decrease since 7:00 on January 12)
	Water level of Reactor Building	O.P.+ 4,202 mm (9 mm decrease since 7:00 on January 12)	O.P.+ 3,136 mm (10 mm increase since 7:00 on January 12)	O.P.+ 3,366 mm (13 mm increase since 7:00 on January 12)	O.P.+ 3,112 mm (7 mm decrease since 7:00 on January 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,304 mm (Increase from initial level:5,521 mm, 61 mm decrease since 7:00 on January 12) O.P.+ 2,864 mm (Increase from initial level:3,590 mm, 251 mm decrease since 7:00 on January 12) O.P.+ 4,307 mm (Water level from floor:511 mm, 6 mm increase since 7:00 on January 12)		
Situation of transfer of the accumulated water		—	—	Condensate Storage Tank →Basement of Unit 2 Turbine Building Currently transferred (From 10:15 on January 12 to 12:50 on January 12)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:30 on January 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:04 on January 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.