

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 13)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 13)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,994 mm (17 mm decrease since 16:00 on January 12)	O.P.+ 3,142 mm (5 mm decrease since 16:00 on January 12)	—
	Water level of Turbine Building	O.P.+ 3,165 mm (9 mm increase since 16:00 on January 12)	O.P.+ 2,982 mm (15 mm decrease since 16:00 on January 12)	O.P.+ 3,072 mm (26 mm decrease since 16:00 on January 12)	O.P.+ 3,088 mm (1 mm increase since 16:00 on January 12)
	Water level of Reactor Building	O.P.+ 4,198 mm (4 mm decrease since 16:00 on January 12)	O.P.+ 3,140 mm (4 mm increase since 16:00 on January 12)	O.P.+ 3,354 mm (12 mm decrease since 16:00 on January 12)	O.P.+ 3,108 mm (4 mm decrease since 16:00 on January 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,340 mm (Increase from initial level:5,557 mm, 36 mm increase since 16:00 on January 12) O.P.+ 2,843 mm (Increase from initial level:3,569 mm, 21 mm decrease since 16:00 on January 12) O.P.+ 4,319 mm (Water level from floor:523 mm, 12 mm increase since 16:00 on January 12)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:55 on January 12 to 7:58 on January 13)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:59 on January 12 to 8:03 on January 13)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:30 on January 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:04 on January 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.