

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 13)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 13)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,014 mm (20 mm increase since 7:00 on January 13)	O.P.+ 3,140 mm (2 mm decrease since 7:00 on January 13)	—
	Water level of Turbine Building	O.P.+ 3,172 mm (7 mm increase since 7:00 on January 13)	O.P.+ 3,000 mm (18 mm increase since 7:00 on January 13)	O.P.+ 3,088 mm (16 mm increase since 7:00 on January 13)	O.P.+ 3,085 mm (3 mm decrease since 7:00 on January 13)
	Water level of Reactor Building	O.P.+ 4,199 mm (1 mm increase since 7:00 on January 13)	O.P.+ 3,150 mm (10 mm increase since 7:00 on January 13)	O.P.+ 3,361 mm (7 mm increase since 7:00 on January 13)	O.P.+ 3,104 mm (4 mm decrease since 7:00 on January 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,310 mm (Increase from initial level:5,527 mm, 30 mm decrease since 7:00 on January 13) O.P.+ 2,694 mm (Increase from initial level:3,420 mm, 149 mm decrease since 7:00 on January 13) O.P.+ 4,329 mm (Water level from floor:533 mm, 10 mm increase since 7:00 on January 13)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:46 on January 13)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:54 on January 13)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:30 on January 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:04 on January 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.