

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 14)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 14)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,950 mm (64 mm decrease since 16:00 on January 13)	O.P.+ 3,123 mm (17 mm decrease since 16:00 on January 13)	—
	Water level of Turbine Building	O.P.+ 3,183 mm (11 mm increase since 16:00 on January 13)	O.P.+ 2,940 mm (60 mm decrease since 16:00 on January 13)	O.P.+ 3,039 mm (49 mm decrease since 16:00 on January 13)	O.P.+ 3,077 mm (8 mm decrease since 16:00 on January 13)
	Water level of Reactor Building	O.P.+ 4,195 mm (4 mm decrease since 16:00 on January 13)	O.P.+ 3,102 mm (48 mm decrease since 16:00 on January 13)	O.P.+ 3,318 mm (43 mm decrease since 16:00 on January 13)	O.P.+ 3,091 mm (13 mm decrease since 16:00 on January 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,436 mm (Increase from initial level:5,653 mm, 126 mm increase since 16:00 on January 13) O.P.+ 3,041 mm (Increase from initial level:3,767 mm, 347 mm increase since 16:00 on January 13) O.P.+ 4,341 mm (Water level from floor:545 mm, 12 mm increase since 16:00 on January 13)		
Situation of transfer of the accumulated water		—	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 14:46 on January 13 to 8:07 on January 14)	Basement of Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 14:54 on January 13 to 8:11 on January 14)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:30 on January 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:04 on January 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.