Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 15)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 15)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,030 mm (52 mm increase since 16:00 on January 14)	O.P.+ 3,130 mm (13 mm increase since 16:00 on January 14)	_
	Water level of Turbine Building	O.P.+ 3,199 mm (11 mm increase since 16:00 on January 14)	O.P.+ 3,013 mm (45 mm increase since 16:00 on January 14)	O.P.+ 3,088 mm (23 mm increase since 16:00 on January 14)	O.P.+ 3,065 mm (4 mm increase since 16:00 on January 14)
	Water level of Reactor Building	O.P.+ 4,186 mm (5 mm decrease since 16:00 on January 14)	O.P.+ 3,158 mm (47 mm increase since 16:00 on January 14)	O.P.+ 3,361 mm (26 mm increase since 16:00 on January 14)	O.P.+ 3,086 mm (4 mm increase since 16:00 on January 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	 O.P.+ 4,279 mm (Increase from initial level:5,496 mm, 118 mm decrease since 16:00 on January 14) O.P.+ 2,477 mm (Increase from initial level:3,203 mm, 356 mm decrease since 16:00 on January 14) O.P.+ 4,361 mm (Water level from floor:565 mm, 12 mm increase since 16:00 on January 14) 		
Situation of transfer of the accumulated water		_	Transfer suspended	Transfer suspended	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:30 on January 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:04 on January 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					