

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 15)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 15)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,049 mm (19 mm increase since 7:00 on January 15)	O.P.+ 3,135 mm (5 mm increase since 7:00 on January 15)	—
	Water level of Turbine Building	O.P.+ 3,205 mm (6 mm increase since 7:00 on January 15)	O.P.+ 3,031 mm (18 mm increase since 7:00 on January 15)	O.P.+ 3,089 mm (1 mm increase since 7:00 on January 15)	O.P.+ 3,073 mm (8 mm increase since 7:00 on January 15)
	Water level of Reactor Building	O.P.+ 4,186 mm (No change since 7:00 on January 15)	O.P.+ 3,182 mm (24 mm increase since 7:00 on January 15)	O.P.+ 3,369 mm (8 mm increase since 7:00 on January 15)	O.P.+ 3,092 mm (6 mm increase since 7:00 on January 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,233 mm (Increase from initial level:5,450 mm, 46 mm decrease since 7:00 on January 15) O.P.+ 2,333 mm (Increase from initial level:3,059 mm, 144 mm decrease since 7:00 on January 15) O.P.+ 4,369 mm (Water level from floor:573 mm, 8 mm increase since 7:00 on January 15)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:57 on January 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:48 on January 15)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:30 on January 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:04 on January 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.