

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 16)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 16)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,978 mm (71 mm decrease since 16:00 on January 15)	O.P.+ 3,112 mm (23 mm decrease since 16:00 on January 15)	—
	Water level of Turbine Building	O.P.+ 3,215 mm (10 mm increase since 16:00 on January 15)	O.P.+ 2,966 mm (65 mm decrease since 16:00 on January 15)	O.P.+ 3,034 mm (55 mm decrease since 16:00 on January 15)	O.P.+ 3,060 mm (13 mm decrease since 16:00 on January 15)
	Water level of Reactor Building	O.P.+ 4,184 mm (2 mm decrease since 16:00 on January 15)	O.P.+ 3,130 mm (52 mm decrease since 16:00 on January 15)	O.P.+ 3,317 mm (52 mm decrease since 16:00 on January 15)	O.P.+ 3,082 mm (10 mm decrease since 16:00 on January 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,379 mm (Increase from initial level:5,596 mm, 146 mm increase since 16:00 on January 15) O.P.+ 2,673 mm (Increase from initial level:3,399 mm, 340 mm increase since 16:00 on January 15) O.P.+ 4,382 mm (Water level from floor:586 mm, 13 mm increase since 16:00 on January 15)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:57 on January 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:48 on January 15)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:30 on January 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:04 on January 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.