Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 16)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water ^{**} (at 16:00 on January 16)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,941 mm (37 mm decrease since 7:00 on January 16)	O.P.+ 3,103 mm (9 mm decrease since 7:00 on January 16)	—
	Water level of Turbine Building	O.P.+ 3,221 mm (6 mm increase since 7:00 on January 16)	O.P.+ 2,932 mm (34 mm decrease since 7:00 on January 16)	O.P.+ 3,010 mm (24 mm decrease since 7:00 on January 16)	O.P.+ 3,047 mm (13 mm decrease since 7:00 on January 16)
	Water level of Reactor Building	O.P.+ 4,181 mm (3 mm decrease since 7:00 on January 16)	O.P.+ 3,099 mm (31 mm decrease since 7:00 on January 16)	O.P.+ 3,292 mm (25 mm decrease since 7:00 on January 16)	O.P.+ 3,071 mm (11 mm decrease since 7:00 on January 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	 O.P.+ 4,456 mm (Increase from initial level:5,673 mm, 77 mm increase since 7:00 on January 16) O.P.+ 3,019 mm (Increase from initial level:3,745 mm, 346 mm increase since 7:00 on January 16) O.P.+ 4,390 mm (Water level from floor:594 mm, 8 mm increase since 7:00 on January 16) 		
Situation of transfer of the accumulated water		_	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:57 on January 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:48 on January 15)	_
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:30 on January 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:17 on January 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 9:13 am on January 16, 2011, we suspended the second cesium absorption apparatus due to reverse cleaning of the filters because the amount of disposal water of the second cesium absorption apparatus decreased gradually. We restarted the apparatus at 12:12 pm on the same day. At 12:17 pm on the same day, the flow rate reached steady state.				