

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 17)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 17)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,881 mm (60 mm decrease since 16:00 on January 16)	O.P.+ 3,080 mm (23 mm decrease since 16:00 on January 16)	—
	Water level of Turbine Building	O.P.+ 3,231 mm (10 mm increase since 16:00 on January 16)	O.P.+ 2,877 mm (55 mm decrease since 16:00 on January 16)	O.P.+ 2,973 mm (37 mm decrease since 16:00 on January 16)	O.P.+ 3,029 mm (18 mm decrease since 16:00 on January 16)
	Water level of Reactor Building	O.P.+ 4,173 mm (8 mm decrease since 16:00 on January 16)	O.P.+ 3,046 mm (53 mm decrease since 16:00 on January 16)	O.P.+ 3,255 mm (37 mm decrease since 16:00 on January 16)	O.P.+ 3,051 mm (20 mm decrease since 16:00 on January 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,561 mm (Increase from initial level:5,778 mm, 105 mm increase since 16:00 on January 16) O.P.+ 3,286 mm (Increase from initial level:4,012 mm, 267 mm increase since 16:00 on January 16) O.P.+ 4,402 mm (Water level from floor:606 mm, 12 mm increase since 16:00 on January 16)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:57 on January 15)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently being transferred (Since 14:48 on January 15)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 15:30 on January 11 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:17 on January 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.