

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 17)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 17)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,861 mm (20 mm decrease since 7:00 on January 17)	O.P.+ 3,065 mm (15 mm decrease since 7:00 on January 17)	—
	Water level of Turbine Building	O.P.+ 3,237 mm (6 mm increase since 7:00 on January 17)	O.P.+ 2,861 mm (16 mm decrease since 7:00 on January 17)	O.P.+ 2,970 mm (3 mm decrease since 7:00 on January 17)	O.P.+ 3,010 mm (19 mm decrease since 7:00 on January 17)
	Water level of Reactor Building	O.P.+ 4,168 mm (5 mm decrease since 7:00 on January 17)	O.P.+ 3,018 mm (28 mm decrease since 7:00 on January 17)	O.P.+ 3,241 mm (14 mm decrease since 7:00 on January 17)	O.P.+ 3,038 mm (13 mm decrease since 7:00 on January 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,604 mm (Increase from initial level:5,821 mm, 43 mm increase since 7:00 on January 17) O.P.+ 3,357 mm (Increase from initial level:4,083 mm, 71 mm increase since 7:00 on January 17) O.P.+ 4,410 mm (Water level from floor:614 mm, 8 mm increase since 7:00 on January 17)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 14:57 on January 15 to 14:10 on January 17)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 14:48 on January 15 to 14:14 on January 17)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:10 on January 17 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:17 on January 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	The cesium adsorption apparatus has been under suspension due to instant outage of Yonomiri Line 1 and 2 since 4:10 pm on January 17.				

For quick publication of the data of water level, values are provided as reference values.