

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 18)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 18)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,922 mm (61 mm increase since 16:00 on January 17)	O.P.+ 3,065 mm (No change since 16:00 on January 17)	—
	Water level of Turbine Building	O.P.+ 3,246 mm (9 mm increase since 16:00 on January 17)	O.P.+ 2,913 mm (52 mm increase since 16:00 on January 17)	O.P.+ 3,016 mm (46 mm increase since 16:00 on January 17)	O.P.+ 3,005 mm (5 mm decrease since 16:00 on January 17)
	Water level of Reactor Building	O.P.+ 4,165 mm (3 mm decrease since 16:00 on January 17)	O.P.+ 3,063 mm (45 mm increase since 16:00 on January 17)	O.P.+ 3,288 mm (47 mm increase since 16:00 on January 17)	O.P.+ 3,025 mm (13 mm decrease since 16:00 on January 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,547 mm (Increase from initial level:5,764 mm, 57 mm decrease since 16:00 on January 17) O.P.+ 2,844 mm (Increase from initial level:3,570 mm, 513 mm decrease since 16:00 on January 17) O.P.+ 4,428 mm (Water level from floor:632 mm, 18 mm increase since 16:00 on January 17)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building Transfer suspended (Since 14:10 on January 17)	Basement of Unit 3 Turbine Building Transfer suspended (Since 14:14 on January 17)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:17 on January 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	The cesium adsorption apparatus has been under suspension due to instant outage of Yonomiri Line 1 and 2 since 4:10 pm on January 17. We restarted the apparatus at 6:42 pm on the same day. At 6:45 pm on the same day, the flow rate reached steady state.				

For quick publication of the data of water level, values are provided as reference values.