

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 19)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 19)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,025 mm (28 mm increase since 7:00 on January 19)	O.P.+ 3,092 mm (7 mm increase since 7:00 on January 19)	—
	Water level of Turbine Building	O.P.+ 3,264 mm (4 mm increase since 7:00 on January 19)	O.P.+ 3,008 mm (25 mm increase since 7:00 on January 19)	O.P.+ 3,048 mm (8 mm increase since 7:00 on January 19)	O.P.+ 3,023 mm (6 mm increase since 7:00 on January 19)
	Water level of Reactor Building	O.P.+ 4,180 mm (6 mm increase since 7:00 on January 19)	O.P.+ 3,157 mm (26 mm increase since 7:00 on January 19)	O.P.+ 3,325 mm (9 mm increase since 7:00 on January 19)	O.P.+ 3,047 mm (8 mm increase since 7:00 on January 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,376 mm (Increase from initial level:5,593 mm, 60 mm decrease since 7:00 on January 19) O.P.+ 2,283 mm (Increase from initial level:3,009 mm, 11 mm increase since 7:00 on January 19) O.P.+ 4,451 mm (Water level from floor:655 mm, 9 mm increase since 7:00 on January 19)		
Situation of transfer of the accumulated water		—	Transfer suspended	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:53 on January 19 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	Transfer temporarily suspended due to vessel replacement				

For quick publication of the data of water level, values are provided as reference values.