Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 20)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 20)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,070 mm (45 mm increase since 16:00 on January 19)	O.P.+ 3,103 mm (11 mm increase since 16:00 on January 19)	_
	Water level of Turbine Building	O.P.+ 3,272 mm (8 mm increase since 16:00 on January 19)	O.P.+ 3,049 mm (41 mm increase since 16:00 on January 19)	O.P.+ 3,061 mm (13 mm increase since 16:00 on January 19)	O.P.+ 3,036 mm (13 mm increase since 16:00 on January 19)
	Water level of Reactor Building	O.P.+ 4,190 mm (10 mm increase since 16:00 on January 19)	O.P.+ 3,199 mm (42 mm increase since 16:00 on January 19)	O.P.+ 3,340 mm (15 mm increase since 16:00 on January 19)	O.P.+ 3,058 mm (11 mm increase since 16:00 on January 19)
	Water level of each building in the Centralized Radiation Waste	Process Main Building	O.P.+ 4,272 mm (Increase from initial level:5,489 mm, 104 mm decrease since 16:00 on January 19)		
		High Temperature Incinerator Building	O.P.+ 1,997 mm (Increase from initial level:2,723 mm, 286 mm decrease since 16:00 on January 19)		
	Treatment Facility	On-site Bunker Building	O.P.+ 4,464 mm (Water level from floor:668 mm, 13 mm increase since 16:00 on January 19)		
Situation of transfer of the accumulated water		_	Transfer suspended	Transfer suspended	_
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation			
		2nd Cesium Adsorption Apparatus (Sarry): Since 20:30 on January 19 In operation			
		Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					
				- I Park - Company of the Company of	