

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 20)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 20)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,092 mm (22 mm increase since 7:00 on January 20)	O.P.+ 3,108 mm (5 mm increase since 7:00 on January 20)	—
	Water level of Turbine Building	O.P.+ 3,274 mm (2 mm increase since 7:00 on January 20)	O.P.+ 3,067 mm (18 mm increase since 7:00 on January 20)	O.P.+ 3,063 mm (2 mm increase since 7:00 on January 20)	O.P.+ 3,042 mm (6 mm increase since 7:00 on January 20)
	Water level of Reactor Building	O.P.+ 4,196 mm (6 mm increase since 7:00 on January 20)	O.P.+ 3,222 mm (23 mm increase since 7:00 on January 20)	O.P.+ 3,346 mm (6 mm increase since 7:00 on January 20)	O.P.+ 3,062 mm (4 mm increase since 7:00 on January 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,219 mm (Increase from initial level:5,436 mm, 53 mm decrease since 7:00 on January 20) O.P.+ 1,795 mm (Increase from initial level:2,521 mm, 202 mm decrease since 7:00 on January 20) O.P.+ 4,472 mm (Water level from floor:676 mm, 8 mm increase since 7:00 on January 20)		
Situation of transfer of the accumulated water		Basement of Unit 1 Turbine Building →Basement of Unit 2 Turbine Building Currently being transferred (Since 15:37 on January 20)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:23 on January 20)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:17 on January 20)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 20:30 on January 19 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.