

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 22)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water※ (at 16:00 on January 22)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,226 mm (28 mm increase since 7:00 on January 22)	O.P.+ 3,097 mm (10 mm increase since 7:00 on January 22)	—
	Water level of Turbine Building	O.P.+ 2,623 mm (39 mm decrease since 7:00 on January 22)	O.P.+ 3,186 mm (26 mm increase since 7:00 on January 22)	O.P.+ 3,045 mm (6 mm increase since 7:00 on January 22)	O.P.+ 3,027 mm (7 mm increase since 7:00 on January 22)
	Water level of Reactor Building	O.P.+ 4,295 mm (54 mm increase since 7:00 on January 22)	O.P.+ 3,350 mm (42 mm increase since 7:00 on January 22)	O.P.+ 3,332 mm (13 mm increase since 7:00 on January 22)	O.P.+ 3,050 mm (9 mm increase since 7:00 on January 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,916 mm (Increase from initial level:5,133 mm, 49 mm decrease since 7:00 on January 22) O.P.+ 1,868 mm (Increase from initial level:2,594 mm, 123 mm decrease since 7:00 on January 22) O.P.+ 4,527 mm (Water level from floor:731 mm, 11 mm increase since 7:00 on January 22)		
Situation of transfer of the accumulated water		Basement of Unit 1 Turbine Building →Basement of Unit 2 Turbine Building Currently transferred (From 15:37 on January 20 to 10:03 on January 20)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:33 on January 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:30 on January 22)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 20:30 on January 19 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.