

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 23)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 23)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,167 mm (59 mm decrease since 16:00 on January 22)	O.P.+ 3,081 mm (16 mm decrease since 16:00 on January 22)	—
	Water level of Turbine Building	O.P.+ 2,635 mm (12 mm increase since 16:00 on January 22)	O.P.+ 3,134 mm (52 mm decrease since 16:00 on January 22)	O.P.+ 2,994 mm (51 mm decrease since 16:00 on January 22)	O.P.+ 3,022 mm (5 mm decrease since 16:00 on January 22)
	Water level of Reactor Building	O.P.+ 4,348 mm (53 mm increase since 16:00 on January 22)	O.P.+ 3,302 mm (48 mm decrease since 16:00 on January 22)	O.P.+ 3,285 mm (47 mm decrease since 16:00 on January 22)	O.P.+ 3,043 mm (7 mm decrease since 16:00 on January 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,827 mm (Increase from initial level:5,044 mm, 89 mm decrease since 16:00 on January 22) O.P.+ 2,470 mm (Increase from initial level:3,196 mm, 602 mm increase since 16:00 on January 22) O.P.+ 4,544 mm (Water level from floor:748 mm, 17 mm increase since 16:00 on January 22)		
Situation of transfer of the accumulated water		Transfer suspended	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:33 on January 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:30 on January 22)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 20:30 on January 19 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.