

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 23)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 23)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,138 mm (29 mm decrease since 7:00 on January 23)	O.P.+ 3,069 mm (12 mm decrease since 7:00 on January 23)	—
	Water level of Turbine Building	O.P.+ 2,641 mm (6 mm increase since 7:00 on January 23)	O.P.+ 3,107 mm (27 mm decrease since 7:00 on January 23)	O.P.+ 2,972 mm (22 mm decrease since 7:00 on January 23)	O.P.+ 3,010 mm (12 mm decrease since 7:00 on January 23)
	Water level of Reactor Building	O.P.+ 4,355 mm (7 mm increase since 7:00 on January 23)	O.P.+ 3,274 mm (28 mm decrease since 7:00 on January 23)	O.P.+ 3,260 mm (25 mm decrease since 7:00 on January 23)	O.P.+ 3,020 mm (23 mm decrease since 7:00 on January 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,857 mm (Increase from initial level:5,074 mm, 30 mm increase since 7:00 on January 23) O.P.+ 2,852 mm (Increase from initial level:3,578 mm, 382 mm increase since 7:00 on January 23) O.P.+ 4,347 mm (Water level from floor:551 mm, 197 mm decrease since 7:00 on January 23)		
Situation of transfer of the accumulated water		Transfer suspended	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:33 on January 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)  Currently transferred (From 14:30 on January 22 to 15:45 on January 23)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 20:30 on January 19 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	From 10:36 to 15:51 on January 23, we transferred accumulated water from On-site Bunker Building to Process Main Building.				

For quick publication of the data of water level, values are provided as reference values.