

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 24)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 24)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,093 mm (45 mm decrease since 16:00 on January 23)	O.P.+ 3,073 mm (4 mm increase since 16:00 on January 23)	—
	Water level of Turbine Building	O.P.+ 2,652 mm (11 mm increase since 16:00 on January 23)	O.P.+ 3,068 mm (39 mm decrease since 16:00 on January 23)	O.P.+ 3,020 mm (48 mm increase since 16:00 on January 23)	O.P.+ 3,008 mm (2 mm decrease since 16:00 on January 23)
	Water level of Reactor Building	O.P.+ 4,339 mm (16 mm decrease since 16:00 on January 23)	O.P.+ 3,226 mm (48 mm decrease since 16:00 on January 23)	O.P.+ 3,299 mm (39 mm increase since 16:00 on January 23)	O.P.+ 3,027 mm (7 mm increase since 16:00 on January 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,772 mm (Increase from initial level:4,989 mm, 85 mm decrease since 16:00 on January 23) O.P.+ 2,995 mm (Increase from initial level:3,721 mm, 143 mm increase since 16:00 on January 23) O.P.+ 4,361 mm (Water level from floor:565 mm, 14 mm increase since 16:00 on January 23)		
Situation of transfer of the accumulated water		Transfer suspended	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:33 on January 22)	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:35 on January 24 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	As there is a gradual lowering of throughput of the second cesium adsorption adsorption apparatus (Sarry), it is temporarily stopped to backwash its filter.				

For quick publication of the data of water level, values are provided as reference values.