

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 24)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 24)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,111 mm (18 mm increase since 7:00 on January 24)	O.P.+ 3,083 mm (10 mm increase since 7:00 on January 24)	—
	Water level of Turbine Building	O.P.+ 2,657 mm (5 mm increase since 7:00 on January 24)	O.P.+ 3,083 mm (15 mm increase since 7:00 on January 24)	O.P.+ 3,027 mm (7 mm increase since 7:00 on January 24)	O.P.+ 3,009 mm (1 mm increase since 7:00 on January 24)
	Water level of Reactor Building	O.P.+ 4,327 mm (12 mm decrease since 7:00 on January 24)	O.P.+ 3,231 mm (5 mm increase since 7:00 on January 24)	O.P.+ 3,311 mm (12 mm increase since 7:00 on January 24)	O.P.+ 3,032 mm (5 mm increase since 7:00 on January 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,731 mm (Increase from initial level:4,948 mm, 41 mm decrease since 7:00 on January 24) O.P.+ 3,091 mm (Increase from initial level:3,817 mm, 96 mm increase since 7:00 on January 24) O.P.+ 4,369 mm (Water level from floor:573 mm, 8 mm increase since 7:00 on January 24)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:36 on January 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:24 on January 24)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:03 on January 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	As there is a gradual lowering of throughput of the second cesium adsorption adsorption apparatus, the apparatus was temporarily stopped at 8:35 today and its filter was washed. The apparatus was restarted at 14:55 on the same day and was reached to the steady-state throughput at 15:03.				

For quick publication of the data of water level, values are provided as reference values.