Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 25)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 25)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,084 mm (29 mm increase since 7:00 on January 25)	O.P.+ 3,061 mm (4 mm decrease since 7:00 on January 25)	_
	Water level of Turbine Building	O.P.+ 2,673 mm (6 mm increase since 7:00 on January 25)	O.P.+ 3,058 mm (26 mm increase since 7:00 on January 25)	O.P.+ 2,996 mm (22 mm increase since 7:00 on January 25)	O.P.+ 2,993 mm (7 mm decrease since 7:00 on January 25)
	Water level of Reactor Building	O.P.+ 4,299 mm (12 mm decrease since 7:00 on January 25)	O.P.+ 3,204 mm (8 mm increase since 7:00 on January 25)	O.P.+ 3,274 mm (10 mm increase since 7:00 on January 25)	O.P.+ 3,018 mm (8 mm decrease since 7:00 on January 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	 O.P.+ 3,930 mm (Increase from initial level:5,147 mm, impossible to compare to the data as of 7:00 on January 25 O.P.+ 2,896 mm (Increase from initial level:3,622 mm, 249 mm decrease since 7:00 on January 25) O.P.+ 4,395 mm (Water level from floor:599 mm, 10 mm increase since 7:00 on January 25) 		
Situation of transfer of the accumulated water					
		_	Transfer suspended	Transfer suspended	_
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation			
		2nd Cesium Adsorption Apparatus (Sarry): Since 15:03 on January 24 In operation			
		Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	No comparative data was aquired due to trouble of the camera (as of 7:00 on January 25)				