

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 26)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 26)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,065 mm (19 mm decrease since 16:00 on January 25)	O.P.+ 3,056 mm (5 mm decrease since 16:00 on January 25)	—
	Water level of Turbine Building	O.P.+ 2,683 mm (10 mm increase since 16:00 on January 25)	O.P.+ 3,042 mm (16 mm decrease since 16:00 on January 25)	O.P.+ 2,968 mm (28 mm decrease since 16:00 on January 25)	O.P.+ 2,993 mm (No change since 16:00 on January 25)
	Water level of Reactor Building	O.P.+ 4,282 mm (17 mm decrease since 16:00 on January 25)	O.P.+ 3,205 mm (1 mm increase since 16:00 on January 25)	O.P.+ 3,264 mm (10 mm decrease since 16:00 on January 25)	O.P.+ 3,015 mm (3 mm decrease since 16:00 on January 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,029 mm (Increase from initial level:5,246 mm, 99 mm increase since 16:00 on January 25) O.P.+ 2,797 mm (Increase from initial level:3,523 mm, 99 mm decrease since 16:00 on January 25) O.P.+ 4,410 mm (Water level from floor:614 mm, 15 mm increase since 16:00 on January 25)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:42 on January 25 to 8:13 on January 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:53 on January 25 to 8:18 on January 26)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:03 on January 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.