

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 26)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 26)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,094 mm (29 mm increase since 7:00 on January 26)	O.P.+ 3,054 mm (2 mm decrease since 7:00 on January 26)	—
	Water level of Turbine Building	O.P.+ 2,696 mm (13 mm increase since 7:00 on January 26)	O.P.+ 3,069 mm (27 mm increase since 7:00 on January 26)	O.P.+ 2,991 mm (23 mm increase since 7:00 on January 26)	O.P.+ 2,994 mm (1 mm increase since 7:00 on January 26)
	Water level of Reactor Building	O.P.+ 4,269 mm (13 mm decrease since 7:00 on January 26)	O.P.+ 3,215 mm (10 mm increase since 7:00 on January 26)	O.P.+ 3,274 mm (10 mm increase since 7:00 on January 26)	O.P.+ 3,010 mm (5 mm decrease since 7:00 on January 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,996 mm (Increase from initial level:5,213 mm, 33 mm decrease since 7:00 on January 26) O.P.+ 2,607 mm (Increase from initial level:3,333 mm, 190 mm decrease since 7:00 on January 26) O.P.+ 4,417 mm (Water level from floor:621 mm, 7 mm increase since 7:00 on January 26)		
Situation of transfer of the accumulated water		—	Transfer suspended	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:03 on January 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.