

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 27)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 27)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,074 mm (20 mm decrease since 16:00 on January 26)	O.P.+ 3,050 mm (4 mm decrease since 16:00 on January 26)	—
	Water level of Turbine Building	O.P.+ 2,706 mm (10 mm increase since 16:00 on January 26)	O.P.+ 3,049 mm (20 mm decrease since 16:00 on January 26)	O.P.+ 2,959 mm (32 mm decrease since 16:00 on January 26)	O.P.+ 2,978 mm (16 mm decrease since 16:00 on January 26)
	Water level of Reactor Building	O.P.+ 4,255 mm (14 mm decrease since 16:00 on January 26)	O.P.+ 3,213 mm (2 mm decrease since 16:00 on January 26)	O.P.+ 3,259 mm (15 mm decrease since 16:00 on January 26)	O.P.+ 3,009 mm (1 mm decrease since 16:00 on January 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,080 mm (Increase from initial level:5,297 mm, 84 mm increase since 16:00 on January 26) O.P.+ 2,585 mm (Increase from initial level:3,311 mm, 22 mm decrease since 16:00 on January 26) O.P.+ 4,431 mm (Water level from floor:635 mm, 14 mm increase since 16:00 on January 26)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:44 on January 26 to 8:14 on January 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:40 on January 26 to 8:10 on January 27)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:03 on January 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.