

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 28)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 28)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,078 mm (23 mm decrease since 16:00 on January 27)	O.P.+ 3,043 mm (7 mm decrease since 16:00 on January 27)	—
	Water level of Turbine Building	O.P.+ 2,721 mm (10 mm increase since 16:00 on January 27)	O.P.+ 3,052 mm (20 mm decrease since 16:00 on January 27)	O.P.+ 2,951 mm (31 mm decrease since 16:00 on January 27)	O.P.+ 2,976 mm (4 mm decrease since 16:00 on January 27)
	Water level of Reactor Building	O.P.+ 4,235 mm (11 mm decrease since 16:00 on January 27)	O.P.+ 3,218 mm (3 mm decrease since 16:00 on January 27)	O.P.+ 3,255 mm (16 mm decrease since 16:00 on January 27)	O.P.+ 3,002 mm (1 mm decrease since 16:00 on January 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,138 mm (Increase from initial level:5,355 mm, 86 mm increase since 16:00 on January 27) O.P.+ 2,451 mm (Increase from initial level:3,177 mm, 18 mm increase since 16:00 on January 27) O.P.+ 4,453 mm (Water level from floor:657 mm, 13 mm increase since 16:00 on January 27)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:51 on January 27 to 8:29 on January 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:48 on January 27 to 8:31 on January 28)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:03 on January 24 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.