

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 30)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 30)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,085 mm (25 mm decrease since 16:00 on January 29)	O.P.+ 3,032 mm (5 mm decrease since 16:00 on January 29)	—
	Water level of Turbine Building	O.P.+ 2,752 mm (9 mm increase since 16:00 on January 29)	O.P.+ 3,056 mm (22 mm decrease since 16:00 on January 29)	O.P.+ 2,937 mm (30 mm decrease since 16:00 on January 29)	O.P.+ 2,956 mm (11 mm decrease since 16:00 on January 29)
	Water level of Reactor Building	O.P.+ 4,220 mm (2 mm increase since 16:00 on January 29)	O.P.+ 3,223 mm (5 mm decrease since 16:00 on January 29)	O.P.+ 3,242 mm (17 mm decrease since 16:00 on January 29)	O.P.+ 2,989 mm (2 mm decrease since 16:00 on January 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,259 mm (Increase from initial level:5,476 mm, 96 mm increase since 16:00 on January 29) O.P.+ 2,244 mm (Increase from initial level:2,970 mm, 63 mm decrease since 16:00 on January 29) O.P.+ 4,512 mm (Water level from floor:716 mm, 18 mm increase since 16:00 on January 29)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:45 on January 29 to 8:19 on January 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building / High Temperature Incinerator Building) Currently transferred (From 21:50 on January 29 to 8:23 on January 30)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:18 on January 29 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.