

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 30)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 30)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,111 mm (26 mm increase since 7:00 on January 30)	O.P.+ 3,034 mm (2 mm increase since 7:00 on January 30)	—
	Water level of Turbine Building	O.P.+ 2,761 mm (9 mm increase since 7:00 on January 30)	O.P.+ 3,080 mm (24 mm increase since 7:00 on January 30)	O.P.+ 2,961 mm (24 mm increase since 7:00 on January 30)	O.P.+ 2,960 mm (4 mm increase since 7:00 on January 30)
	Water level of Reactor Building	O.P.+ 4,222 mm (2 mm increase since 7:00 on January 30)	O.P.+ 3,231 mm (8 mm increase since 7:00 on January 30)	O.P.+ 3,251 mm (9 mm increase since 7:00 on January 30)	O.P.+ 2,983 mm (6 mm decrease since 7:00 on January 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,261 mm (Increase from initial level:5,478 mm, 2 mm increase since 7:00 on January 30) O.P.+ 2,080 mm (Increase from initial level:2,806 mm, 164 mm decrease since 7:00 on January 30) O.P.+ 4,523 mm (Water level from floor:727 mm, 11 mm increase since 7:00 on January 30)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:05 on January 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:12 on January 30)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 18:45 on January 17 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:18 on January 29 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.