

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on January 31)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on January 31)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,063 mm (48 mm decrease since 16:00 on January 30)	O.P.+ 3,027 mm (7 mm decrease since 16:00 on January 30)	—
	Water level of Turbine Building	O.P.+ 2,771 mm (10 mm increase since 16:00 on January 30)	O.P.+ 3,036 mm (44 mm decrease since 16:00 on January 30)	O.P.+ 2,946 mm (15 mm decrease since 16:00 on January 30)	O.P.+ 2,959 mm (1 mm decrease since 16:00 on January 30)
	Water level of Reactor Building	O.P.+ 4,226 mm (4 mm increase since 16:00 on January 30)	O.P.+ 3,205 mm (26 mm decrease since 16:00 on January 30)	O.P.+ 3,244 mm (7 mm decrease since 16:00 on January 30)	O.P.+ 2,981 mm (2 mm decrease since 16:00 on January 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,133 mm (Increase from initial level:5,350 mm, 128 mm decrease since 16:00 on January 30) O.P.+ 2,394 mm (Increase from initial level:3,120 mm, 314 mm increase since 16:00 on January 30) O.P.+ 4,541 mm (Water level from floor:745 mm, 18 mm increase since 16:00 on January 30)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:05 on January 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:12 on January 30)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:18 on January 29 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.