

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on January 31)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on January 31)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,057 mm (6 mm decrease since 7:00 on January 31)	O.P.+ 3,022 mm (5 mm decrease since 7:00 on January 31)	—
	Water level of Turbine Building	O.P.+ 2,777 mm (6 mm increase since 7:00 on January 31)	O.P.+ 3,031 mm (5 mm decrease since 7:00 on January 31)	O.P.+ 2,941 mm (5 mm decrease since 7:00 on January 31)	O.P.+ 2,953 mm (6 mm decrease since 7:00 on January 31)
	Water level of Reactor Building	O.P.+ 4,235 mm (9 mm increase since 7:00 on January 31)	O.P.+ 3,193 mm (12 mm decrease since 7:00 on January 31)	O.P.+ 3,239 mm (5 mm decrease since 7:00 on January 31)	O.P.+ 2,977 mm (4 mm decrease since 7:00 on January 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,161 mm (Increase from initial level:5,378 mm, 28 mm increase since 7:00 on January 31) O.P.+ 2,509 mm (Increase from initial level:3,235 mm, 115 mm increase since 7:00 on January 31) O.P.+ 4,319 mm (Water level from floor:523 mm, 222 mm decrease since 7:00 on January 31)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:05 on January 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:12 on January 30)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:18 on January 29 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	From 9:35 to 15:33 on January 31, the accumulated water was transferred from the On-site Bunker Building to the Process Main Building.				

For quick publication of the data of water level, values are provided as reference values.