

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 1)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on February 1)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,056 mm (1 mm decrease since 16:00 on January 31)	O.P.+ 3,018 mm (4 mm decrease since 16:00 on January 31)	—
	Water level of Turbine Building	O.P.+ 2,786 mm (9 mm increase since 16:00 on January 31)	O.P.+ 3,030 mm (1 mm decrease since 16:00 on January 31)	O.P.+ 2,932 mm (9 mm decrease since 16:00 on January 31)	O.P.+ 2,941 mm (12 mm decrease since 16:00 on January 31)
	Water level of Reactor Building	O.P.+ 4,248 mm (13 mm increase since 16:00 on January 31)	O.P.+ 3,194 mm (1 mm increase since 16:00 on January 31)	O.P.+ 3,233 mm (6 mm decrease since 16:00 on January 31)	O.P.+ 2,972 mm (5 mm decrease since 16:00 on January 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,040 mm (Increase from initial level:5,257 mm, 121 mm decrease since 16:00 on January 31) O.P.+ 2,664 mm (Increase from initial level:3,390 mm, 155 mm increase since 16:00 on January 31) O.P.+ 4,334 mm (Water level from floor:538 mm, 15 mm increase since 16:00 on January 31)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:05 on January 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:12 on January 30)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:18 on January 29 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					