

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 1)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on February 1)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,056 mm (No change since 7:00 on February 1)	O.P.+ 3,016 mm (2 mm decrease since 7:00 on February 1)	—
	Water level of Turbine Building	O.P.+ 2,793 mm (7 mm increase since 7:00 on February 1)	O.P.+ 3,030 mm (No change since 7:00 on February 1)	O.P.+ 2,929 mm (3 mm decrease since 7:00 on February 1)	O.P.+ 2,942 mm (1 mm increase since 7:00 on February 1)
	Water level of Reactor Building	O.P.+ 4,260 mm (12 mm increase since 7:00 on February 1)	O.P.+ 3,196 mm (2 mm increase since 7:00 on February 1)	O.P.+ 3,231 mm (2 mm decrease since 7:00 on February 1)	O.P.+ 2,967 mm (5 mm decrease since 7:00 on February 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,975 mm (Increase from initial level:5,192 mm, 65 mm decrease since 7:00 on February 1) O.P.+ 2,784 mm (Increase from initial level:3,510 mm, 120 mm increase since 7:00 on February 1) O.P.+ 4,342 mm (Water level from floor:546 mm, 8 mm increase since 7:00 on February 1)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:05 on January 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:12 on January 30)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:18 on January 29 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.