

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 2)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on February 2)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,054 mm (2 mm decrease since 16:00 on February 1)	O.P.+ 3,011 mm (5 mm decrease since 16:00 on February 1)	—
	Water level of Turbine Building	O.P.+ 2,802 mm (9 mm increase since 16:00 on February 1)	O.P.+ 3,028 mm (2 mm decrease since 16:00 on February 1)	O.P.+ 2,921 mm (8 mm decrease since 16:00 on February 1)	O.P.+ 2,937 mm (5 mm decrease since 16:00 on February 1)
	Water level of Reactor Building	O.P.+ 4,271 mm (11 mm increase since 16:00 on February 1)	O.P.+ 3,196 mm (No change since 16:00 on February 1)	O.P.+ 3,219 mm (12 mm decrease since 16:00 on February 1)	O.P.+ 2,957 mm (10 mm decrease since 16:00 on February 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,860 mm (Increase from initial level:5,077 mm, 115 mm decrease since 16:00 on February 1) O.P.+ 3,024 mm (Increase from initial level:3,750 mm, 240 mm increase since 16:00 on February 1) O.P.+ 4,358 mm (Water level from floor:562 mm, 16 mm increase since 16:00 on February 1)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:05 on January 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:12 on January 30)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:36 on February 2 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	As the processing volume at 2nd Cesium absorption apparatus (SALLY) was on a downward trend, in order to backwash the filter, we suspended operation.				

For quick publication of the data of water level, values are provided as reference values.