

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 2)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water※ (at 16:00 on February 2)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,052 mm (2 mm decrease since 7:00 on February 2)	O.P.+ 3,005 mm (6 mm decrease since 7:00 on February 2)	—
	Water level of Turbine Building	O.P.+ 2,808 mm (6 mm increase since 7:00 on February 2)	O.P.+ 3,027 mm (1 mm decrease since 7:00 on February 2)	O.P.+ 2,917 mm (4 mm decrease since 7:00 on February 2)	O.P.+ 2,932 mm (5 mm decrease since 7:00 on February 2)
	Water level of Reactor Building	O.P.+ 4,274 mm (3 mm increase since 7:00 on February 2)	O.P.+ 3,195 mm (1 mm decrease since 7:00 on February 2)	O.P.+ 3,218 mm (1 mm decrease since 7:00 on February 2)	O.P.+ 2,958 mm (1 mm increase since 7:00 on February 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,794 mm (Increase from initial level:5,011 mm, 66 mm decrease since 7:00 on February 2) O.P.+ 3,242 mm (Increase from initial level:3,968 mm, 218 mm increase since 7:00 on February 2) O.P.+ 4,366 mm (Water level from floor:570 mm, 8 mm increase since 7:00 on February 2)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:05 on January 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:12 on January 30)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:15 on February 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	※ As there is a gradual lowering of throughput of the second cesium adsorption adsorption apparatus, the apparatus was temporarily stopped at 8:36 today and its filter was washed. The apparatus was restarted at 11:12 on the same day and was reached to the steady-state throughput at 11:15.				

※ For quick publication of the data of water level, values are provided as reference values.