

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 3)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on February 3)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,044 mm (8 mm decrease since 16:00 on February 2)	O.P.+ 2,996 mm (9 mm decrease since 16:00 on February 2)	—
	Water level of Turbine Building	O.P.+ 2,818 mm (10 mm increase since 16:00 on February 2)	O.P.+ 3,019 mm (8 mm decrease since 16:00 on February 2)	O.P.+ 2,909 mm (8 mm decrease since 16:00 on February 2)	O.P.+ 2,920 mm (12 mm decrease since 16:00 on February 2)
	Water level of Reactor Building	O.P.+ 4,268 mm (6 mm decrease since 16:00 on February 2)	O.P.+ 3,187 mm (8 mm decrease since 16:00 on February 2)	O.P.+ 3,210 mm (8 mm decrease since 16:00 on February 2)	O.P.+ 2,951 mm (7 mm decrease since 16:00 on February 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,682 mm (Increase from initial level:4,899 mm, 112 mm decrease since 16:00 on February 2) O.P.+ 3,415 mm (Increase from initial level:4,141 mm, 173 mm increase since 16:00 on February 2) O.P.+ 4,379 mm (Water level from floor:583 mm, 13 mm increase since 16:00 on February 2)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:05 on January 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:12 on January 30)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:15 on February 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.