

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 3)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on February 3)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,065 mm (21 mm increase since 7:00 on February 3)	O.P.+ 2,998 mm (2 mm increase since 7:00 on February 3)	—
	Water level of Turbine Building	O.P.+ 2,823 mm (5 mm increase since 7:00 on February 3)	O.P.+ 3,037 mm (18 mm increase since 7:00 on February 3)	O.P.+ 2,924 mm (15 mm increase since 7:00 on February 3)	O.P.+ 2,923 mm (3 mm increase since 7:00 on February 3)
	Water level of Reactor Building	O.P.+ 4,265 mm (3 mm decrease since 7:00 on February 3)	O.P.+ 3,195 mm (8 mm increase since 7:00 on February 3)	O.P.+ 3,220 mm (10 mm increase since 7:00 on February 3)	O.P.+ 2,948 mm (3 mm decrease since 7:00 on February 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,618 mm (Increase from initial level:4,835 mm, 64 mm decrease since 7:00 on February 3) O.P.+ 3,255 mm (Increase from initial level:3,981 mm, 160 mm decrease since 7:00 on February 3) O.P.+ 4,388 mm (Water level from floor:592 mm, 9 mm increase since 7:00 on February 3)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:07 on February 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently transferred (From 16:12 on January 30 to 10:12 on February 3)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:15 on February 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.