

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 4)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on February 4)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,054 mm (11 mm decrease since 16:00 on February 3)	O.P.+ 3,013 mm (15 mm increase since 16:00 on February 3)	—
	Water level of Turbine Building	O.P.+ 2,832 mm (9 mm increase since 16:00 on February 3)	O.P.+ 3,027 mm (10 mm decrease since 16:00 on February 3)	O.P.+ 2,942 mm (18 mm increase since 16:00 on February 3)	O.P.+ 2,932 mm (9 mm increase since 16:00 on February 3)
	Water level of Reactor Building	O.P.+ 4,265 mm (No change since 16:00 on February 3)	O.P.+ 3,196 mm (1 mm increase since 16:00 on February 3)	O.P.+ 3,243 mm (23 mm increase since 16:00 on February 3)	O.P.+ 2,956 mm (8 mm increase since 16:00 on February 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,508 mm (Increase from initial level:4,725 mm, 110 mm decrease since 16:00 on February 3) O.P.+ 3,140 mm (Increase from initial level:3,866 mm, 115 mm decrease since 16:00 on February 3) O.P.+ 4,403 mm (Water level from floor:607 mm, 15 mm increase since 16:00 on February 3)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:07 on February 3)	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:15 on February 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.