

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 5)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on February 5)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,041 mm (3 mm decrease since 7:00 on February 5)	O.P.+ 3,031 mm (4 mm decrease since 7:00 on February 5)	—
	Water level of Turbine Building	O.P.+ 2,852 mm (5 mm increase since 7:00 on February 5)	O.P.+ 3,013 mm (4 mm decrease since 7:00 on February 5)	O.P.+ 2,954 mm (10 mm decrease since 7:00 on February 5)	O.P.+ 2,953 mm (3 mm increase since 7:00 on February 5)
	Water level of Reactor Building	O.P.+ 4,258 mm (5 mm decrease since 7:00 on February 5)	O.P.+ 3,182 mm (4 mm decrease since 7:00 on February 5)	O.P.+ 3,263 mm (4 mm decrease since 7:00 on February 5)	O.P.+ 2,977 mm (5 mm increase since 7:00 on February 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,267 mm (Increase from initial level:4,484 mm, 66 mm decrease since 7:00 on February 5) O.P.+ 3,081 mm (Increase from initial level:3,807 mm, 94 mm increase since 7:00 on February 5) O.P.+ 4,434 mm (Water level from floor:638 mm, 10 mm increase since 7:00 on February 5)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:07 on February 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:49 on February 5)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 11:15 on February 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.