

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 6)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on February 6)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,036 mm (5 mm decrease since 16:00 on February 5)	O.P.+ 3,024 mm (7 mm decrease since 16:00 on February 5)	—
	Water level of Turbine Building	O.P.+ 2,861 mm (9 mm increase since 16:00 on February 5)	O.P.+ 3,008 mm (5 mm decrease since 16:00 on February 5)	O.P.+ 2,938 mm (16 mm decrease since 16:00 on February 5)	O.P.+ 2,946 mm (7 mm decrease since 16:00 on February 5)
	Water level of Reactor Building	O.P.+ 4,256 mm (2 mm decrease since 16:00 on February 5)	O.P.+ 3,179 mm (3 mm decrease since 16:00 on February 5)	O.P.+ 3,246 mm (17 mm decrease since 16:00 on February 5)	O.P.+ 2,973 mm (4 mm decrease since 16:00 on February 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,183 mm (Increase from initial level:4,400 mm, 84 mm decrease since 16:00 on February 5) O.P.+ 3,371 mm (Increase from initial level:4,097 mm, 290 mm increase since 16:00 on February 5) O.P.+ 4,445 mm (Water level from floor:649 mm, 11 mm increase since 16:00 on February 5)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently transferred (From 16:07 on February 3 to 8:47 on February 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:49 on February 5)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): From 11:15 on February 2 to 8:40 on February 6 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.