

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 6)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on February 6)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,063 mm (27 mm increase since 7:00 on February 6)	O.P.+ 3,020 mm (4 mm decrease since 7:00 on February 6)	—
	Water level of Turbine Building	O.P.+ 2,867 mm (6 mm increase since 7:00 on February 6)	O.P.+ 3,032 mm (24 mm increase since 7:00 on February 6)	O.P.+ 2,932 mm (6 mm decrease since 7:00 on February 6)	O.P.+ 2,943 mm (3 mm decrease since 7:00 on February 6)
	Water level of Reactor Building	O.P.+ 4,255 mm (1 mm decrease since 7:00 on February 6)	O.P.+ 3,194 mm (15 mm increase since 7:00 on February 6)	O.P.+ 3,240 mm (6 mm decrease since 7:00 on February 6)	O.P.+ 2,970 mm (3 mm decrease since 7:00 on February 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,140 mm (Increase from initial level:4,357 mm, 43 mm decrease since 7:00 on February 6) O.P.+ 3,567 mm (Increase from initial level:4,293 mm, 196 mm increase since 7:00 on February 6) O.P.+ 4,453 mm (Water level from floor:657 mm, 8 mm increase since 7:00 on February 6)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer suspended (Since 8:47 on February 6)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:49 on February 5)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on February 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:40 am, we temporally suspended the second cesium adsorption apparatus to conduct backwash of the filter since gradual decrease in the flow volume of treatment was confirmed. At 1:25 pm, we initiated the apparatus and the flow volume reached at normal level (34 m3/h) at 1:33 pm.				

For quick publication of the data of water level, values are provided as reference values.