

Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 7)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on February 7)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,116 mm (53 mm increase since 16:00 on February 6)	O.P.+ 3,014 mm (6 mm decrease since 16:00 on February 6)	—
	Water level of Turbine Building	O.P.+ 2,878 mm (11 mm increase since 16:00 on February 6)	O.P.+ 3,080 mm (48 mm increase since 16:00 on February 6)	O.P.+ 2,923 mm (9 mm decrease since 16:00 on February 6)	O.P.+ 2,940 mm (3 mm decrease since 16:00 on February 6)
	Water level of Reactor Building	O.P.+ 4,279 mm (24 mm increase since 16:00 on February 6)	O.P.+ 3,247 mm (53 mm increase since 16:00 on February 6)	O.P.+ 3,231 mm (9 mm decrease since 16:00 on February 6)	O.P.+ 2,963 mm (7 mm decrease since 16:00 on February 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,070 mm (Increase from initial level:4,287 mm, 70 mm decrease since 16:00 on February 6) O.P.+ 3,375 mm (Increase from initial level:4,101 mm, 192 mm decrease since 16:00 on February 6) O.P.+ 4,470 mm (Water level from floor:674 mm, 17 mm increase since 16:00 on February 6)		
Situation of transfer of the accumulated water		—	Transfer suspended	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 9:49 on February 5)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on February 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.