

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 7)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on February 7)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,142 mm (26 mm increase since 7:00 on February 7)	O.P.+ 3,015 mm (1 mm increase since 7:00 on February 7)	—
	Water level of Turbine Building	O.P.+ 2,889 mm (11 mm increase since 7:00 on February 7)	O.P.+ 3,102 mm (22 mm increase since 7:00 on February 7)	O.P.+ 2,929 mm (6 mm increase since 7:00 on February 7)	O.P.+ 2,937 mm (3 mm decrease since 7:00 on February 7)
	Water level of Reactor Building	O.P.+ 4,322 mm (43 mm increase since 7:00 on February 7)	O.P.+ 3,275 mm (28 mm increase since 7:00 on February 7)	O.P.+ 3,234 mm (3 mm increase since 7:00 on February 7)	O.P.+ 2,962 mm (1 mm decrease since 7:00 on February 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,029 mm (Increase from initial level:4,246 mm, 41 mm decrease since 7:00 on February 7) O.P.+ 3,276 mm (Increase from initial level:4,002 mm, 99 mm decrease since 7:00 on February 7) O.P.+ 4,479 mm (Water level from floor:683 mm, 9 mm increase since 7:00 on February 7)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:14 on February 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently transferred (From 9:49 on February 5 to 13:56 on February 7)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on February 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.