

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 9)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on February 9)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,133 mm (1 mm decrease since 16:00 on February 8)	O.P.+ 3,052 mm (13 mm increase since 16:00 on February 8)	—
	Water level of Turbine Building	O.P.+ 2,917 mm (10 mm increase since 16:00 on February 8)	O.P.+ 3,095 mm (1 mm decrease since 16:00 on February 8)	O.P.+ 2,979 mm (14 mm increase since 16:00 on February 8)	O.P.+ 2,961 mm (12 mm increase since 16:00 on February 8)
	Water level of Reactor Building	O.P.+ 4,340 mm (6 mm decrease since 16:00 on February 8)	O.P.+ 3,272 mm (1 mm increase since 16:00 on February 8)	O.P.+ 3,287 mm (16 mm increase since 16:00 on February 8)	O.P.+ 2,983 mm (11 mm increase since 16:00 on February 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,850 mm (Increase from initial level:4,067 mm, 70 mm decrease since 16:00 on February 8) O.P.+ 2,976 mm (Increase from initial level:3,702 mm, 107 mm decrease since 16:00 on February 8) O.P.+ 4,528 mm (Water level from floor:732 mm, 19 mm increase since 16:00 on February 8)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:14 on February 7)	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on February 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.