

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 9)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on February 9)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,134 mm (1 mm increase since 7:00 on February 9)	O.P.+ 3,060 mm (8 mm increase since 7:00 on February 9)	—
	Water level of Turbine Building	O.P.+ 2,923 mm (6 mm increase since 7:00 on February 9)	O.P.+ 3,096 mm (1 mm increase since 7:00 on February 9)	O.P.+ 2,988 mm (9 mm increase since 7:00 on February 9)	O.P.+ 2,970 mm (9 mm increase since 7:00 on February 9)
	Water level of Reactor Building	O.P.+ 4,334 mm (6 mm decrease since 7:00 on February 9)	O.P.+ 3,274 mm (2 mm increase since 7:00 on February 9)	O.P.+ 3,295 mm (8 mm increase since 7:00 on February 9)	O.P.+ 2,989 mm (6 mm increase since 7:00 on February 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,809 mm (Increase from initial level:4,026 mm, 41 mm decrease since 7:00 on February 9) O.P.+ 2,930 mm (Increase from initial level:3,656 mm, 46 mm decrease since 7:00 on February 9) O.P.+ 4,538 mm (Water level from floor:742 mm, 10 mm increase since 7:00 on February 9)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:14 on February 7)	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:33 on February 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.