

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 10)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on February 10)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,134 mm (No change since 16:00 on February 9)	O.P.+ 3,072 mm (12 mm increase since 16:00 on February 9)	—
	Water level of Turbine Building	O.P.+ 2,932 mm (9 mm increase since 16:00 on February 9)	O.P.+ 3,097 mm (1 mm increase since 16:00 on February 9)	O.P.+ 3,000 mm (12 mm increase since 16:00 on February 9)	O.P.+ 2,978 mm (8 mm increase since 16:00 on February 9)
	Water level of Reactor Building	O.P.+ 4,322 mm (12 mm decrease since 16:00 on February 9)	O.P.+ 3,278 mm (4 mm increase since 16:00 on February 9)	O.P.+ 3,308 mm (13 mm increase since 16:00 on February 9)	O.P.+ 3,000 mm (11 mm increase since 16:00 on February 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,744 mm (Increase from initial level:3,961 mm, 65 mm decrease since 16:00 on February 9) O.P.+ 2,865 mm (Increase from initial level:3,591 mm, 65 mm decrease since 16:00 on February 9) O.P.+ 4,554 mm (Water level from floor:758 mm, 16 mm increase since 16:00 on February 9)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently transferred (From 14:14 on February 7 to 8:21 on February 10)	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): From 13:33 on February 6 to 8:39 on February 10 Operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	8:39 second cesium adoption facility suspended for filter cleaning 8:45 transfer initited from the side bnka buiding to process main building.				

For quick publication of the data of water level, values are provided as reference values.