

# **Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 10)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on February 10)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,159 mm (25 mm increase since 7:00 on February 10)	O.P.+ 3,079 mm (7 mm increase since 7:00 on February 10)	—
	Water level of Turbine Building	O.P.+ 2,939 mm (7 mm increase since 7:00 on February 10)	O.P.+ 3,119 mm (22 mm increase since 7:00 on February 10)	O.P.+ 3,008 mm (8 mm increase since 7:00 on February 10)	O.P.+ 2,987 mm (9 mm increase since 7:00 on February 10)
	Water level of Reactor Building	O.P.+ 4,318 mm (4 mm decrease since 7:00 on February 10)	O.P.+ 3,296 mm (18 mm increase since 7:00 on February 10)	O.P.+ 3,316 mm (8 mm increase since 7:00 on February 10)	O.P.+ 3,008 mm (8 mm increase since 7:00 on February 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,772 mm (Increase from initial level:3,989 mm, 28 mm increase since 7:00 on February 10) O.P.+ 2,898 mm (Increase from initial level:3,624 mm, 33 mm increase since 7:00 on February 10) O.P.+ 4,289 mm (Water level from floor:493 mm, 265 mm decrease since 7:00 on February 10)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:32 on February 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	2/10 8:39 2nd cesium adoption facility suspended for filter cleaning. 14:19 activated, 14:32 back to normal operation 2/10 8:45 ~ 16:39 accumurated water transferred from sit banka building to process main building.				

For quick publication of the data of water level, values are provided as reference values.