

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 11)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on February 11)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,117 mm (42 mm decrease since 16:00 on February 10)	O.P.+ 3,091 mm (12 mm increase since 16:00 on February 10)	—
	Water level of Turbine Building	O.P.+ 2,948 mm (9 mm increase since 16:00 on February 10)	O.P.+ 3,081 mm (38 mm decrease since 16:00 on February 10)	O.P.+ 3,020 mm (12 mm increase since 16:00 on February 10)	O.P.+ 2,996 mm (9 mm increase since 16:00 on February 10)
	Water level of Reactor Building	O.P.+ 4,311 mm (7 mm decrease since 16:00 on February 10)	O.P.+ 3,272 mm (24 mm decrease since 16:00 on February 10)	O.P.+ 3,330 mm (14 mm increase since 16:00 on February 10)	O.P.+ 3,019 mm (11 mm increase since 16:00 on February 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,717 mm (Increase from initial level:3,934 mm, 55 mm decrease since 16:00 on February 10) O.P.+ 2,961 mm (Increase from initial level:3,687 mm, 63 mm increase since 16:00 on February 10) O.P.+ 4,279 mm (Water level from floor:483 mm, 10 mm decrease since 16:00 on February 10)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:32 on February 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.