

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 11)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on February 11)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,097 mm (20 mm decrease since 7:00 on February 11)	O.P.+ 3,100 mm (9 mm increase since 7:00 on February 11)	—
	Water level of Turbine Building	O.P.+ 2,955 mm (7 mm increase since 7:00 on February 11)	O.P.+ 3,063 mm (18 mm decrease since 7:00 on February 11)	O.P.+ 3,027 mm (7 mm increase since 7:00 on February 11)	O.P.+ 3,007 mm (11 mm increase since 7:00 on February 11)
	Water level of Reactor Building	O.P.+ 4,307 mm (4 mm decrease since 7:00 on February 11)	O.P.+ 3,255 mm (17 mm decrease since 7:00 on February 11)	O.P.+ 3,337 mm (7 mm increase since 7:00 on February 11)	O.P.+ 3,025 mm (6 mm increase since 7:00 on February 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,677 mm (Increase from initial level:3,894 mm, 40 mm decrease since 7:00 on February 11) O.P.+ 3,004 mm (Increase from initial level:3,730 mm, 43 mm increase since 7:00 on February 11) O.P.+ 4,285 mm (Water level from floor:489 mm, 6 mm increase since 7:00 on February 11)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	Transfer suspended	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:32 on February 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.