

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 12)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 7:00 on February 12)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,063 mm (34 mm decrease since 16:00 on February 11)	O.P.+ 3,110 mm (10 mm increase since 16:00 on February 11)	—
	Water level of Turbine Building	O.P.+ 2,964 mm (9 mm increase since 16:00 on February 11)	O.P.+ 3,032 mm (31 mm decrease since 16:00 on February 11)	O.P.+ 3,040 mm (13 mm increase since 16:00 on February 11)	O.P.+ 3,006 mm (1 mm decrease since 16:00 on February 11)
	Water level of Reactor Building	O.P.+ 4,300 mm (7 mm decrease since 16:00 on February 11)	O.P.+ 3,228 mm (27 mm decrease since 16:00 on February 11)	O.P.+ 3,351 mm (14 mm increase since 16:00 on February 11)	O.P.+ 3,037 mm (12 mm increase since 16:00 on February 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,610 mm (Increase from initial level:3,827 mm, 67 mm decrease since 16:00 on February 11) O.P.+ 3,090 mm (Increase from initial level:3,816 mm, 86 mm increase since 16:00 on February 11) O.P.+ 4,300 mm (Water level from floor:504 mm, 15 mm increase since 16:00 on February 11)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	—	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:32 on February 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.