

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on February 12)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on February 12)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,044 mm (19 mm decrease since 7:00 on February 12)	O.P.+ 3,106 mm (4 mm decrease since 7:00 on February 12)	—
	Water level of Turbine Building	O.P.+ 2,971 mm (7 mm increase since 7:00 on February 12)	O.P.+ 3,015 mm (17 mm decrease since 7:00 on February 12)	O.P.+ 3,030 mm (10 mm decrease since 7:00 on February 12)	O.P.+ 3,022 mm (16 mm increase since 7:00 on February 12)
	Water level of Reactor Building	O.P.+ 4,296 mm (4 mm decrease since 7:00 on February 12)	O.P.+ 3,212 mm (16 mm decrease since 7:00 on February 12)	O.P.+ 3,345 mm (6 mm decrease since 7:00 on February 12)	O.P.+ 3,042 mm (5 mm increase since 7:00 on February 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,609 mm (Increase from initial level:3,826 mm, 1 mm decrease since 7:00 on February 12) O.P.+ 3,150 mm (Increase from initial level:3,876 mm, 60 mm increase since 7:00 on February 12) O.P.+ 4,307 mm (Water level from floor:511 mm, 7 mm increase since 7:00 on February 12)		
Situation of transfer of the accumulated water		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 9:57 on February 12)	—
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:32 on February 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.