

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on February 13)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water※ (at 7:00 on February 13)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,014 mm (30 mm decrease since 16:00 on February 12)	O.P.+ 3,099 mm (7 mm decrease since 16:00 on February 12)	—
	Water level of Turbine Building	O.P.+ 2,980 mm (9 mm increase since 16:00 on February 12)	O.P.+ 2,989 mm (26 mm decrease since 16:00 on February 12)	O.P.+ 3,012 mm (18 mm decrease since 16:00 on February 12)	O.P.+ 3,023 mm (1 mm increase since 16:00 on February 12)
	Water level of Reactor Building	O.P.+ 4,289 mm (7 mm decrease since 16:00 on February 12)	O.P.+ 3,190 mm (22 mm decrease since 16:00 on February 12)	O.P.+ 3,327 mm (18 mm decrease since 16:00 on February 12)	O.P.+ 3,039 mm (3 mm decrease since 16:00 on February 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 2,642 mm (Increase from initial level:3,859 mm, 33 mm increase since 16:00 on February 12) O.P.+ 3,259 mm (Increase from initial level:3,985 mm, 109 mm increase since 16:00 on February 12) O.P.+ 4,323 mm (Water level from floor:527 mm, 16 mm increase since 16:00 on February 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on February 10)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) — (Since 9:57 on February 12)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 13:47 on January 30 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 14:32 on February 10 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.